



CUSTOMER QUOTATION NO. 5517

Chris Mott
Skymills Condo CCN 1411286 c/o C-Era
Property Management
Suite B, 6010 12th Street SE
Calgary Alberta T2H 2X3

Date: 2024/02/23
Quote No: 5517
Site: Skymills Condo 2000
Site Contact: Shantelle Thapa
Site Phone: 403-266-0240
Salesperson: Wyatt Fairweather
Valid For: 30 Day(s)

Description

During a recent Preventative Maintenance visit the following deficiency was found:

Asset ID: 1305

Asset Type: Boiler

Make: Lochinvar

Model: CBN0747

Location: Mechanical Room

Asset Test Notes: Relief valve leaking, this is a **safety device and must be replaced.**

Scope of Work:

- Set up protection of property
- Isolate & drain appliance
- Supply and install:
 - One (1) Safety Relief Valve
- Commission and test
- Site clean up

Priority: **High**

Delivery: **Stock Items**

Note(s):

- Quotation assumes isolations hold.
- All additional work will be completed at time and material, client will be notified should any issues arise.



CUSTOMER QUOTATION NO. 5517

Priority Legend:		Sub-Total ex Tax	\$869.78
High = Asset is in need of immediate action		Tax	\$43.49
Medium = Asset will likely fail in the short term		Total inc Tax	\$913.27
Low = Recommended action / budget item			

Sample