

Fire/Smoke System Certificate

Client: Compliance Services Australia

Job: Bert Newton 32-40 Graham Road, Highett – Building 4

Certificate Number: 2262

Reference: Fire/smoke sealing of your various service penetrations as detailed below

FIRE8 Pty. Ltd. certifies that as part of our contracted works, we have carried out the above fire protection at **Bert Newton 32-40 Graham Road, Highett – Building 4** as instructed by **Machi Farooqui** of **Compliance Services Australia**.

These works have been completed and checked using the approved proprietary fire resistance tested products & systems as **per AS1530 part 4 & AS4072 part 1**

Any works that are modified, damaged or disturbed following completion are not covered by this certification.

Installed in accordance with the manufacturer's specifications.

Signed: 

Name: Jarrad Sherry

Date: 30th January, 2026

Works Completed:

Ground Floor – Above Fire Doors Adjacent 51 Item 1

1 x 400mm x 400mm penetration with duct through plaster wall (one side only)

Level 2 to Ground Floor – Hydraulic Riser (Lift Lobby) Item 2

2 x 100mm penetration with PVC pipe (caulk & b fixings) through slab roof

Level 3 – Hydraulic Riser (Lift Lobby) Item 3

Further investigation required – excluded separate price to be provided if required.

