

Fire/Smoke System Certificate

Client: Go Big Constructions Pty Ltd

Job: The George Sandringham – 15 Geoge Street, Sandringham

Certificate Number: 2264

Reference: Fire/smoke sealing of your various service penetrations as detailed below

FIRE8 Pty. Ltd. certifies that as part of our contracted works, we have carried out the above fire protection at **The George Sandringham – 15 Geoge Street, Sandringham** as instructed **Matt Jones** of **Go Big Constructions Pty Ltd**

These works have been completed and checked using the approved proprietary fire resistance tested products & systems as **per AS1530 part 4 & AS4072 part 1**

Any works that are modified, damaged or disturbed following completion are not covered by this certification.

Installed in accordance with the manufacturer's specifications.

Signed: 

Name: Jarrad Sherry

Date: 16th January, 2026

Works Completed:

Level 3 – Stairwell Opposite Apartment 305

1 x 900mm x 900mm penetration with Gortor 2hr fire rated access hatch through slab roof

Level 3 – Stairwell Opposite Apartment 308

1 x 900mm x 900mm penetration with Gortor 2hr fire rated access hatch through slab roof

*Includes 2hr fire rated plaster board wall system extending to existing precast concrete panel forming top/ceiling of stairwell.

FRL: -/120/120

