



LIFE SAFETY LEGEND

TRAVEL DISTANCE TO EXIT	
EXIT SIGN	⊗
EMERGENCY LIGHT	⊕
FIRE EXTINGUISHER	⊖
FIRE EXTINGUISHER CABINET	⊗
SMOKE DETECTOR	⊖
CO2 DETECTOR	⊖

MEANS OF EGRESS REQUIREMENTS

CODE REFERENCE
FBC TABLE 1016.1

A. MAXIMUM TRAVEL DISTANCE

FFPC TABLE 42.2.5

B. MAXIMUM DEAD-END DISTANCE GROUP S-1 – 20 FEET

FBC 1014.3
EXCEPTION

C. MAXIMUM COMMON PATH DISTANCE GROUP S-1 – 100 FEET

FBC 1006.1.3

D. EXIT LIGHTING

FBC 1006.1.4

- MEANS OF EGRESS – 1 FOOT CANDLE AT FLOOR LEVEL WHILE THE BUILDING IS OCCUPIED.
- REQUIRED ILLUMINATION SHOULD BE ARRANGED SO THAT THE FAILURE OF ANY SINGLE LIGHTING UNIT WILL NOT RESULT IN ANY AREA OF LESS THAN 0.2 FOOT CANDLE.

FBC 1006.2.1

- EMERGENCY LIGHTING MUST BE PROVIDED IN THE CORRIDORS, AND PASSAGEWAYS LEADING TO AN EXIT OR PUBLIC WAY.

FBC 1006.2.2

- WHEN CHANGING FROM ONE ENERGY SOURCE TO ANOTHER THE DELAY MUST NOT BE MORE THAN 10 SECONDS.

FBC 006.2.3

- EMERGENCY LIGHTING MUST BE PROVIDED FOR A PERIOD OF 1 ½ HOUR.

FBC 1006.3.1

E. EXIT SIGN

- EXITS MUST BE MARKED BY SIGNS READILY VISIBLE FROM ANY DIRECTION OF EXIT ACCESS.

FBC 1006.3.1

- EXTERNALLY AND INTERNALLY ILLUMINATED EXITS SIGNS MUST BE VISIBLE IN BOTH NORMAL AND EMERGENCY LIGHTING.

FBC 1006.3.2

- EXIT ACCESS MUST BE MARKED BY SIGNS READILY VISIBLE WHERE IN BOTH NORMAL OR WAY IS NOT READILY APPARENT.

FBC 1006.3.2

- SIGN PLACEMENT MUST BE SO THAT NO POINT IN THE EXIT ACCESS IS MORE THAN 100 FEET FROM THE NEAREST EXTERNALLY ILLUMINATED SIGN AND NOT IN THE EXCESS OF THE MARKED RATING FOR INTERNALLY ILLUMINATED SIGNS.

FBC 1006.3.5

- ILLUMINATION EQUAL TO 5 FOOT CANDLES AT THE SURFACE OF AN EXTERNALLY ILLUMINATED EXIT SIGN AND AN INTERNALLY ILLUMINATED SIGN VISIBILITY MUST BE EQUIVALENT.

FBC 1006.3.6

GENERAL NOTES
1. ALL MEASUREMENTS +/-
FIELD VERIFY.

JAMES W. CALDER, AIA
FL Lic# AR15359

DRAWING BY	JWC	07/27/2016
CHECK BY		

ISSUED FOR PLANNING PURPOSE			
NO.	DATE	REVISION	BY
1			

P.J. CALLAGHAN
—CONSTRUCTION—
LICENSE NO. C06088112
COLUMBIA, SC 29902
PH: 572-2855, FAX: 572-4877

THE CRAFTY SQUIRREL
259 CENTRAL AVE
ST PETERSBURG, FL
#16-08001122

JOB #: 2545
DATE: 07/27/2016
SCALE: AS NOTED
SHEET
LS-2