



# MILLS SIGN & PAINTING SERVICE

A.B.N. 95 821 813 146

A.C.N. 008 834 080

## PROTECTIVE COATINGS INSPECTION REPORT

JOB NO:	SB
CLIENT:	
PROJECT:	3 X ROOF PLATFORMS, UNDERSIDE WHITE, TOPSIDE ANTI SLIP PASTEL GREY
DEFECTS OBSERVED:	

DATE	ABRASIVE	BLAST	SURFACE PROFILE	COAT	PRODUCT	COLOUR	BATCH NO.	APPLICATION METHOLD	TIME START	R.H. %	DRY BULB OC	STEEL TEMP.	DEW POINT	TIME FINISH	AVE WET	MAX D.F.T.	MN D.F.T.	AVE D.F.T.	SPECIFIED D.F.T.	REMARKS
------	----------	-------	-----------------	------	---------	--------	-----------	---------------------	------------	--------	-------------	-------------	-----------	-------------	---------	------------	-----------	------------	------------------	---------

27/2/13	G	WHIP		1	AMERON 400	WHITE	AUSP2073 AUSL2103	SPRAY	9.00	42	25	24	11	12.30	300	228	206	217	200	UNDERSIDE OF PLATFORM
28/2/13	G	WHIP		1	AMERLOCK 400	WHITE	AUSF2073 AUSL2103	SPRAY	8.30	45	22	21	9	1.00	150	141	104	122	100	TOP SIDE NON SLIP PLATFORM
1/3/13				2	AMERLOCK 400	PASTEL GREY	AUSK2076 AUSL2103	SPRAY	10.30	38	28	28	14	12.30	200				100	TOP SIDE NON SLIP PLATFORM
15/3/13	G	WHIP		1	AMERLOCK 400	WHITE	AUSF2073 AUSL2103	SPRAY	1.00	59	29	28	19	4.00	300	226	208	217	200	TRUSSES ONE SIDE
18/3/13				1	AMERLOCK 400	WHITE	AUSF2073 AUSL2103	SPRAY	10.00	62	26	25	17	1.30	300	234	211	222	200	TURN TRUSS
20/3/13	G	WHIP		1	AMERLOCK 400	WHITE	AUSF2073 AUSL2103	SPRAY	11.00	61	23	23	13	2.30	300	242	207	224	200	ROOF STRUCTURE & TRUSSES
21/3/13				1	AMERLOCK 400	WHITE	AUSF2073 AUSL2103	SPRAY	9.00	50	21	21	10	12.30	300	237	212	224	200	TURN PAINT OTHER SIDE

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--